



Drawing not to scale

MODEL #		Transformer Typical Installation Detail	
CJ300SSMT		NOTES: • Make sure home run wires are tight in the terminal blocks. Loose/poor connections will melt the block and damage the transformer. • Field repairable breakers, terminals, timer and photocell. • For transformer sizing see CAST "Transformer and System Installation Guide". • For transformer mounting information see "Transformer Stand Detail".	
CJ300PSMT			
Rev. 2-28-03	Plan Symbol:		